

$$\operatorname{\textit{Page}}\ 1$$ of 4 This information was generated by the HP KEYMARK database on 9 Oct 2023

Summary of	Air Source Heat Pump R290-06	Reg. No.	041-K070-01
Certificate Holder			
Name	P.P.U.H "HEGAM"		
Address	ul. Mokra 1	ZIP	42-287
City	Kamienica	Country	Poland
Certification Body	BRE Global Limited		
Subtype title	Air Source Heat Pump R290-06		
Heat Pump Type	Outdoor Air/Water		
Refrigerant	R290		
Mass of Refrigerant	0.55 kg		
Certification Date	09.10.2023		
Testing basis	Heat Pump Keymark Scheme Rules Rev 12		



Model: HPC-06P1

Configure model			
Model name	HPC-06P1		
Application Heating (medium temp)			
Units	Outdoor		
Climate Zone	n/a		
Reversibility	Yes		
Cooling mode application (optional)	n/a		

General Data		
Power supply 1x230V 50Hz		

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	6.07 kW	6.10 kW	
El input	1.27 kW	1.95 kW	
СОР	4.77	3.12	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate



 $$\operatorname{\textit{Page}}\ 3$$ of 4 This information was generated by the HP KEYMARK database on 9 Oct 2023

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level outdoor	60 dB(A)	60 dB(A)	

EN 14825			
	Low temperature	Medium temperature	
η_{s}	190 %	146 %	
Prated	6.08 kW	6.06 kW	
SCOP	4.83	3.71	
Tbiv	-7 °C	-7 °C	
TOL	-10 °C	-10 °C	
Pdh Tj = -7°C	5.37 kW	5.36 kW	
$COPTj = -7^{\circ}C$	3.09	2.33	
Cdh Tj = -7 °C	0.900	0.900	
Pdh Tj = +2°C	3.40 kW	3.33 kW	
COP Tj = +2°C	4.68	3.66	
Cdh Tj = +2 °C	0.900	0.900	
Pdh Tj = +7°C	2.24 kW	2.17 kW	
$COP Tj = +7^{\circ}C$	6.20	4.70	
Cdh Tj = +7 °C	0.900	0.900	
Pdh Tj = 12°C	2.36 kW	2.28 kW	

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 4 This information was generated by the HP KEYMARK database on 9 Oct 2023

COP Tj = 12°C	9.30	7.01
Cdh Tj = +12 °C	0.900	0.900
Pdh Tj = Tbiv	5.37 kW	5.36 kW
COP Tj = Tbiv	3.09	2.33
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	6.03 kW	5.62 kW
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.71	2.06
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900
WTOL	65 °C	65 °C
Poff	10 W	10 W
РТО	30 W	30 W
PSB	10 W	10 W
PCK	42 W	42 W
Supplementary Heater: Type of energy input	Electricity	Electricity
Supplementary Heater: PSUP	0.05 kW	0.44 kW
Annual energy consumption Qhe	2599 kWh	3372 kWh