

Page 1 of 7 This information was generated by the HP KEYMARK database on 9 Oct 2023

Summary of	Air Source Heat Pump R290-18	Reg. No.	041-K070-03	
Certificate Holder				
Name	P.P.U.H "HEGAM"			
Address	ul. Mokra 1	ZIP	42-287	
City	Kamienica	Country	Poland	
Certification Body	BRE Global Limited			
Subtype title	Air Source Heat Pump R290-18			
Heat Pump Type	Outdoor Air/Water			
Refrigerant	R290			
Mass of Refrigerant	1.4 kg			
Certification Date	09.10.2023			
Testing basis	Heat Pump Keymark Scheme Rules Rev 12			

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Model: HPC-18P1

Configure model			
Model name	HPC-18P1		
Application	Heating (medium temp)		
Units	Outdoor		
Climate Zone	n/a		
Reversibility	Yes		
Cooling mode application (optional)	n/a		

General Data		
Power supply 1x230V 50Hz		

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	18.36 kW	18.16 kW	
El input	4.09 kW	6.01 kW	
СОР	4.49	3.02	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
	·	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



This information was generated by the HP KEYMARK database on 9 Oct 2023

EN 12102-1			
	Low temperature	Medium temperature	
Sound power level outdoor	70 dB(A)	72 dB(A)	

EN 14825		
	Low temperature	Medium temperature
η _s	189 %	146 %
Prated	16.27 kW	16.44 kW
SCOP	4.81	3.72
Tbiv	-7 °C	-7 °C
TOL	-10 °C	-10 °C
Pdh Tj = -7°C	14.39 kW	14.54 kW
COP Tj = -7°C	3.01	2.48
Cdh Tj = -7 °C	0.900	0.900
Pdh Tj = +2°C	8.89 kW	8.91 kW
COP Tj = +2°C	4.70	3.52
Cdh Tj = +2 °C	0.900	0.900
Pdh Tj = +7°C	5.64 kW	5.73 kW
COP Tj = +7°C	6.21	4.84
Cdh Tj = +7 °C	0.900	0.900
Pdh Tj = 12°C	5.88 kW	5.52 kW

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 4 of 7

This information was generated by the HP KEYMARK database on 9 Oct 2023

This information was generated by the HP KETMARK database on 9 Oct 2023				
8.74	6.85			
0.900	0.900			
14.39 kW	14.54 kW			
3.01	2.48			
15.98 kW	15.34 kW			
2.59	2.01			
0.900	0.900			
64 °C	64 °C			
14 W	14 W			
29 W	29 W			
14 W	14 W			
42 W	42 W			
Electricity	Electricity			
0.29 kW	1.11 kW			
6987 kWh	9142 kWh			
	 8.74 0.900 14.39 kW 3.01 15.98 kW 2.59 0.900 64 °C 14 W 29 W 29 W 20 W			



Model: HPC-18P3

Configure model			
Model name	HPC-18P3		
Application	Heating (medium temp)		
Units	Outdoor		
Climate Zone	n/a		
Reversibility	Yes		
Cooling mode application (optional)	n/a		

General Data		
Power supply 3x400V 50Hz		

Heating

EN 14511-2			
	Low temperature	Medium temperature	
Heat output	18.42 kW	18.30 kW	
El input	4.01 kW	5.94 kW	
СОР	4.60	3.08	

EN 14511-4		
Shutting off the heat transfer medium flow	passed	
	·	
Complete power supply failure	passed	
Defrost test	passed	
Starting and operating test	passed	

Average Climate

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 6 of 7

This information was generated by the HP KEYMARK database on 9 Oct 2023

EN 12102-1				
	Low temperature	Medium temperature		
Sound power level outdoor	70 dB(A)	72 dB(A)		

EN 14825				
	Low temperature	Medium temperature		
η _s	189 %	145 %		
Prated	16.34 kW	16.40 kW		
SCOP	4.79	3.71		
Tbiv	-7 °C	-7 °C		
TOL	-10 °C	-10 °C		
Pdh Tj = -7°C	14.46 kW	14.51 kW		
COP Tj = -7°C	3.10	2.48		
Cdh Tj = -7 °C	0.900	0.900		
Pdh Tj = +2°C	9.08 kW	9.01 kW		
COP Tj = +2°C	4.71	3.50		
Cdh Tj = +2 °C	0.900	0.900		
Pdh Tj = +7°C	5.69 kW	5.74 kW		
COP Tj = +7°C	6.04	4.82		
Cdh Tj = +7 °C	0.900	0.900		
Pdh Tj = 12°C	5.70 kW	5.47 kW		

EHPA Secretariat | Rue dArlon 63-67 | Phone: +32 2 400 10 17 | Email: secretariat@heatpumpkeymark.com | www.heatpumpkeymark.com



Page 7 of 7 This information was generated by the HP KEYMARK database on 9 Oct 2023

This information was generated by the HP KETMARK database on 9 Oct 2023				
COP Tj = 12°C	7.91	6.91		
Cdh Tj = +12 °C	0.900	0.900		
Pdh Tj = Tbiv	14.46 kW	14.51 kW		
COP Tj = Tbiv	3.10	2.48		
Pdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	16.34 kW	15.20 kW		
COP Tj = TOL or COP Tj = Tdesignh if TOL < Tdesignh	2.78	2.16		
Cdh Tj = TOL or Pdh Tj = Tdesignh if TOL < Tdesignh	0.900	0.900		
WTOL	65 °C	65 °C		
Poff	14 W	14 W		
РТО	29 W	29 W		
PSB	14 W	14 W		
РСК	43 W	43 W		
Supplementary Heater: Type of energy input	Electricity	Electricity		
Supplementary Heater: PSUP	0.00 kW	1.20 kW		
Annual energy consumption Qhe	7052 kWh	9145 kWh		